



Reg. No. 041/P-007

Product Certification Body accredited by
Slovak national accreditation service

NOTIFIED BODY No. 1396
Osloboditeľov 282, 059 35 Batizovce, Slovakia
tel. +421 52 7752298 fax. +421 52 7881412 http://www.fires.sk



EC – CERTIFICATE OF CONFORMITY

1396 – CPD – 0034

In compliance the Directive 89/106/EEC of the Council of European Communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the Construction Products Directive – (CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, it has been stated that the construction product

Natural smoke and heat exhaust ventilators, type DYMKLAP

with properties and use as described in the Initial type-testing report No. C1396/08/0026/5003/SC, issued by FIRES s.r.o., Notified Body 1396, on 14th July 2009;

placed on the market by

REWA Sp. z o.o.

Wola Rafałowska 212a, 36-017 Błędowa Tyczyńska, Poland

and produced in the factory

REWA Sp. z o.o.

Wola Rafałowska 212a, 36-017 Błędowa Tyczyńska, Poland

is submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan and that the notified body - FIRES, s.r.o. - has performed the initial type-testing for the relevant characteristics of the product, the initial inspection of the factory and of the factory production control and performs the continuous surveillance, assessment and approval of the factory production control.

This certificate attests that all provisions concerning the attestation of conformity and the performances described in the Annex ZA of the standard

EN 12101 - 2: 2003

were applied and that the product fulfils all the prescribed requirements.

This certificate was first issued on the 14th July 2009 and remains valid as long as the conditions laid down in the harmonised technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.

Batizovce, 14th July 2009



Ing. Mária Gašperová
Head of Product Certification Body

051502 FIRES 136/C-14/06/2012-E