



APRAGAZ

a.s.b.l.
Your Inspection Authority



Chaussée de Vilvorde, 156 B-1120 Brussels
Phone 32/2/264 03 60 - Fax. 32/2/268 89 58
e-mail : info@apragaz.com - V.A.T. BE 407.199.070

MOBIAK S.A.
96-98 Markou Mpotsari Street
GR – 73136 CHANIA (CRETE)
GREECE

Y/Ref. :
O/Ref. : VDS/BG

Date : 17 May 2023

APPROVAL CERTIFICATE EN 3-7 – PORTABLE FIRE EXTINGUISHERS FOR BUILDINGS
extension of the approval for modification of constructive detail, higher or other fire rating and type.

We hereby declare that the hereafter mentioned extinguishers were type approved according to the requirements of the EN3-7 standards, according to the tests reports and with the hereafter mentioned approval number, by extension of the approvals mentioned on the certificate of (date).

Approval No.	Brand	Type	Nominal Charge	Fire ratings achieved	EN 3-7 test report No.
EN3-23/523	MOBIAK	MBK22-LITHIUM-HGEL-6	6 L HydroGelBM 048	13 A - 25 F	EN 12530
EN3-23/524	MOBIAK	MBK22-LITHIUM-HGEL-9	9 L HydroGelBM 048	21 A	EN 12531

The approval is subject to the continued maintenance of the Quality System of the manufacturer in accordance with the relevant requirements of EN3-10.

The manufacturer is authorized to affix the above mentioned approval number on the marking label of the approved corresponding extinguishers as long as the results of our inspections, periodically made according to the requirements of § 10 of the EN 3-10, are satisfactory.

Nota Bene: additional requirements (i.e. : language of the labels, maintenance requirements, ...) may be made by national regulations and/or quality marks.

Head of Fire Extinguisher Department

Christophe Vanderschriek