CERTIFICATE OF CONSTANCY OF PERFORMANCE

1239/CPR/0818901

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 laying down harmonised conditions for the marketing of construction products, it's certified that the

Construction product:	**External pedestrian doorsets of one leaf according to EN 14351-1 with fire resisting characteristics according to EN 16034 and suitable for evacuation routes**
Scope of Certification: (reference)	**ALTAMIRA 1H** *The certified construction solution is fully described in report No. 104298-1 EXAP in accordance with EN 13501-2.* – **$EI_2$60-C (category A)** – Nominal dimensions: – Frame: Outer: 1.040 x 2.170 mm. / Free pass: 930 x 2.110 mm. – Leaf dimensions without overlap: 955 x 2.115 x 56,2 mm. – High density support construction: ≥ 1.200 kg/m^3 / Thickness ≥ 130 mm.
Supplied and Manufactured by:	**PUERTAS ROPER, S.L.** **Polígono Industrial de Trascueto, Parcela 88-89** **39600 REVILLA (Cantabria) SPAIN**

Is subject to a factory production control and to the inspection of samples in accordance to a prescribed test plan by the manufacturer, and that the Notified Body CERTINALIA, S.L.U. has carried out initial type tests for all relevant characteristics of the product, as well as the initial inspection of the factory and FPC, and the continuous surveillance, assessment and approval of FPC

This certificate shows compliance with all regulations applicable to the conformity assessment in the Annex ZA of the standard

EN 16034:2014
EN 14351-1:2006+A2:2016

and that the product meets the minimum requirements applicable.

System of assessment and verification of constancy of performance: SYSTEM 1

CERTINALIA tecnalia group
Firmado digitalmente por 15966973M CARLOS MANUEL NAZABAL (R: B20991220)
Carlos Nazabal Alsua
Manager

Fecha de entrada de vigor: 31/10/2019
Fecha de actualización 11/12/2025
Válido hasta: 03/02/2029

Nº serie: 081890106-E

ENAC
CERTIFICACIÓN ISO 17065 Nº125 / C-PR343

This document allows the manufacturer to fix the CE mark.
This certificate may be modified, temporarily suspended and withdrawn by CERTINALIA.
The validity of this certificate can be checked through consultation in www.certinalia.com